

DEPARTMENT OF THE ARMY
Omaha District, Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

:NOTICE: Failure to acknowledge : Solicitation No. DACA45 03 R 0034
:all amendments may cause rejec- :
:tion of the offer. See FAR : Date of Issue: 21 NOV 2003
:52.215-1 of Section 00100 : Date of Receiving Proposals:
13 JAN 2004

Amendment No. 0005
8 January 2004

SUBJECT: Amendment No. 0005 to Request for Proposal Solicitation Package
for Design and Construction of REPLACE CENTRAL FIRE ALARM SYSTEM,
PN 3378, IOWA AAP, IOWA.

Solicitation No. DACA45 03 R 0034.

TO: Prospective Offerors and Others Concerned

1. The specifications and drawings for subject project are hereby modified
as follows (revise all specification indices, attachment lists, and drawing
indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Section 13852A, Page 11, to the end of paragraph 2.3.2.5,
Item c., add:

"This connection is not intended to be a permanent connection to the
internet but a connection that can be plugged into or turned on when
the user needs support to fix a problem or download new software."

(2) Section 13852A, Page 12, paragraph 2.3.3, lines 1 and 2,
delete "The remote ... WAN connection." and substitute:

"The remote console shall be connected to the base station with an
existing dedicated optical fiber using a LAN or WAN type protocol."

2. This amendment is a part of the proposing papers and its receipt shall be
acknowledged on the Standard Form 1442. All other conditions and requirements
of the request for proposal remain unchanged. If the proposals have been
mailed prior to receiving this amendment, you will notify the office where
proposals are received, in the specified manner, immediately of its receipt and
of any changes in your proposal occasioned thereby.

a. Hand-Carried Proposals shall be delivered to the U.S. Army Corps
of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th
Street, Omaha, Nebraska 68102-1618.

b. Mailed Proposals shall be addressed as noted in Item 8 on Page
00010-1 of Standard Form 1442.

3. Offers will be received until 1:00 p.m., local time at place of receiving proposals, 13 JAN 2004.

U.S. Army Engineer District, Omaha
Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

8 January 2004
DRL/4547

RESPONSE TO REQUEST FOR INFORMATION

The Radio Type Fire Alarm Reporting System including the Radio Fire Alarm Monitoring Base Station (i.e. the entire system) shall meet the following requirements:

- a. Be UL Listed or FM Approved or approved by a nationally recognized testing laboratory (NRTL) as specified in Section 13852A Paragraphs 1.2.6 and 1.3 (SD-07).
- b. Function as a Proprietary Supervising Station per NFPA 72 as specified in Section 13852A, Paragraphs 1.2.6 and 1.5. A NFPA 1221 system is not required.
- c. Function as outlined in Section 13852A.